



NLC India Limited

('Navratna' - Government of India Enterprise)

Office of the Company Secretary

Corporate Office : Block-1, Neyveli-607 801, Cuddalore District, Tamil Nadu.
Registered Office : First Floor, No.8, Mayor Sathyamurthy Road,
FSD, Egmore Complex of Food Corporation of India, Chetpet, Chennai - 600 031.
CIN : L93090TN1956GOI003507, Website: www.nlcindia.com, email: cosec@nlcindia.com
Phone: 04142-252205, Fax: 04142-252645 & 252646



11.06.2019

To

The Bombay Stock Exchange Ltd
Phiroze JeeJeebhoy Towers
Dalal Street
Mumbai-400 001.
Scrip Code : **513683**

Sir,

Sub: Verification -June 10, 2019 -NLC India Ltd. (513683)

Ref: Your email dated 11.06.2019

With reference to your email dated 11.06.2019 seeking clarification on the News item published in the Business Standard dated 10.06.2019, we wish to furnish the following clarification:

In Thermal Power Station-II (7x210 MW) of NLCIL a fire incident happened on 09-06-2019 A.N in one of the Boilers (Unit-VI, 210 MW) while resuming operation after annual maintenance. This has led to loss of life for one technician and burn injury for another person.

The chronological events are as under.

- On 09.06.2019: At 11:22 AM after over haul, boiler was lighted up for refractory drying with two oil burners in service.
- At 13.24 hrs: There was furnace puffing and smoke emanated from the boiler and the boiler was hand tripped.
- A committee was constituted to make a preliminary assessment of the reasons for the accident and the damages caused and the report was received at 20:00 Hrs on 09.06.2019.


Material impact:

- The company has an installed capacity of 3934.5 MW and the outage unit has the capacity of 210 MW only. This unit of 210 MW is expected to resume its production shortly. Hence, there is no material impact on account of the above incident.

This is for your information and record.

Thanking you

For NLC India Limited


Company Secretary. 11/06/2019